



**CORRIGENDUM-I**

Sub:- Reply to the Prebid queries and Extension of Due Date of Submission of Bids against Tender for Rate Contract for procurement of MCCB with DB.

**Ref : Our Tender Enquiry No. TPCODL /P&S/MCCB with DB/ 26 /20-21.**

With reference to above Tender, the replies to the Prebid queries are attached for reference. Prospective bidders are intimated to note following modification.

Sl. No.	Existing Last Date and Time of submission of bids.	Modified Last Date and Time of submission of bids.
1	Dt.27.07.2020/15.00hrs.	Dt.14.08.2020/15.00Hrs.

**All other terms & conditions of the above tenders are remains un-altered.**

For detail Tender Specification & Terms and Conditions, please visit our website <https://www.tpcentralodisha.com>. Interested bidders to download the tender documents from our website <https://www.tpcentralodisha.com>. Also all future corrigendum if any to the above tenders then it will be informed on our website <https://www.tpcentralodisha.com>.

SI No	Tender Specification	BIDDER'S Comments		TPCODL Comments
1	As per the enquiry - The Panel enclosure shall be of IP:-66	Maximum IP:65 is recomending for this requirement.		The specifications mentioned in the tender are final
2	Type of release	Thermal magnetic or Fully magnetic		thermally magnetic
S. No	Clause & Page No.	Parameter Requirement	BIDDER'S Recommendation	TPCODL Comments
1	Pg No. 4 of TS Clause No 5.2 MCCB, Specification for MCCB with DB	Each Current path and operating contact system of 3 Pole MCCB shall be encapsulate design with double break contacts on incoming and outgoing side of the current path.	We already supplied MCCB's with Single Break contacts to TPDDL, BSES and other Utilities and are performing satisfactory, please amend Double Break to Single Break so that we can also participate in this tender.	Shall be of double break type
2	Event Information Clause No.1.4.9 Page No. 3	Bidder shall submit box sample as per applicable TS in this Tender	Please provide Drawing of DB to understand and quote. Weight of MCCB with DB is more then 50Kgs. Please give relaxation in submission of sample of MCCB with DB.	Acceptable, Sample inspection foe Box will be done thru Webex
3	Annexure VIII EMD BG Format Page No. 20-22 , Clause (i)	Any Claim/extension under the guarantee can be lodge able at issuing outstation bank or at Bhubaneswar branch and claim will also be payable at Bhubaneswar Branch. (To be confirmed by Bhubaneswar Branch by a letter to that effect).	We tried with 3 banks and all are not agreeing on this clause. Please remove this clause from the EMD BG Format./ Advise.	Follow instruction as per clause no 3.1 of Tender Specification.
BIDDER'S QUERY	13. TENDER SAMPLE : Not applicable	1.4.9- Bidder shall submit box sample as per applicable technical specification in this tender. The sample shall be submitted at TPCODL office. A confirmation of submitted sample is to be shared by bidder before tender opening. In case of non-submission of sample, TPCODL reserve the right to reject the bid for further acceptance / evaluation.		Sample checking will be done thru WEBEx
SI No	Description of Points			TPCODL Comments
1	Make list of the component not found in the tender specification			Not understood
2	Specification specified for IP-66, whereas DB asked for single door Please confirm, normally IP-64,65 & 66 are Double door			double door is acceptable
3	AI Busbar de-rating factor not specified, PI specify the de-rating factor, You have specified 1Amp/per sq mm with out de-rating factor			shall be as per specification mentioned in the t
4	In page no 6 of12 of Tech Spec. point no.5.4 last para where specifically mentioned The incoming cable shall be terminated at back side of the bottom of the MCCB distribution box and outgoing cable shall be terminated from front of the bottom of the box, but in page no 4 of12 point no 5.1 para 5 last line specified A cable Box shall be provided at the back side of the MCCB box for incoming cable connection, kindly confirm .			cable box is required
5	Marerials delivery asked for Store / Site, how we can define the transport charges ,PI confirm			Materials will be delivered at Central Store in Choudwar, Cuttack