

TENDER NO. TPCODL/P&S/154/20-21

RATE CONTRACT FOR SUPPLY OF EYE HOOK, SUSPENSION CALMP, DEAD END CLAMP & IPC CONNECTOR FOR A PERIOD OF ONE YEAR

SL. No.	Item Description	LV ABC Details	Bidder Comments	TPCODL Response
1	Supply of SUS. CLAMP with EYE HOOK (Eye Hook: 20 KN Susp. Clamp: 40 KN)	Bare Neutral Messenger Size = ?	Eye Hook: 20 KN Susp. Clamp: 25 KN Kindly provide us the Bare Neutral Messenger Wire size. The Eye Hook and the Suspension Clamp will be as per Bidder design & as per REC requirement. The UTS requirement by the TPCODL is very high, request for reducing the UTS requirement from 45 KN to the value specified in the drawing attached in the specification.	Eyehook: (Pg 98 of Tender doc) UTS for bolted type eyehook as mentioned in Tender technical specification.i.e 20 KN, For Messenger wire Size 150 sqmm, Suspension Clamp: (Pg 100-101 of Tender doc-5.b) UTS for Suspension Clamp-40 KN Suspension clamp to hold Aluminium Alloy messenger wire up to 150 Sqmm As per Tender specification page no. mentioned above
2	Supply of DEAD-END CLAMP (Dead End Clamp; 45 KN)	Bare Neutral Messenger Size = ?	Dead End Clamp: 36 KN Kindly provide us the Bare Neutral Messenger Wire size. The Dead End Clamp will be as per Bidder design & as per REC requirement. The UTS requirement by the TPCODL is very high, request for reducing the UTS requirement from 45 KN to the value specified in the drawing attached in the specification.	Pg. 107-108 of Tender doc-5.8 UTS to be 45 KN to hold Al. alloy messenger wire upto 150 sqmm. As per Tender specification page no. mentioned above
3	Supply of IPC INSULATED PIERCING CONNECTOR (All types of IPC's (Type A, B, C & D) as per EN 50483 standard.)	IPC Type A: Main-50-150 Sq mm, Branch-50-150 Sq mm, Amp-350. IPC Type B: Main-25-150 Sq mm, Branch-6-35 Sq mm, Amp-200. IPC Type C: Main-16-95 Sq mm, Branch-1.5-16 Sq mm, Amp-100. IPC Type D: Main-10-50 Sq mm, Branch-1.5-10 Sq mm, Amp-100.	All tests has been conducted on all types of IPC's as per NF C 33-020 standard which is the major standard followed world over for the LV ABC accessories. Request you to accept the test reports as per NFC standard.	As per tender specifications