

FORMAT B.1**Format for Technical Pre-Bid Queries****Tender No** TPCODL/P&S/100000021/20-21**Package Name** Rate Contract for Supply of Galvanized Wide Parallel Beam (WPB) Pole.**Bidder :**

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately
Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

Pre-Bid Query has to be sent in editable Excel file format only**Pre-Bid Query has to be sent through e-mail in Tata Power E-Tender System**

Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL Response
1	2	3	4	5
1	Sr. 1.7 (C) Qualification Criteria	WPB or RSJ must be mfg. by Main Makes - SAIL / TATA JINDAL or Billets of Main make may be rerolled in reqd. WPB or RSJ section	Can we buy material from re-rollers using Main producer/s (SAIL / TATA / JINDAL / RINL) Billets & Blooms. TC's of (RM) Billets & Blooms will be from Main producer's and TC's (FM) of WPB / RSJ will be from re-rollers	Not accepted. As per 1.7 (C) Qualification Criteria c) WPB must be manufactured by Main Makes (SAIL,Jindal, TATA) or Billet from Main make may be rerolled in the required WPB or RSJ section.
2	Annex II B, Sr No. 5, Delivery	The material shall be delivered within 60 days from issue of appvd. drg's or issue of RO whichever is later	Delivery shall be within 90 days from issuance of "Release Order" as RM is from Main producer/s - SAIL / TATA / JINDAL / RINL is never delivered in timely manner or Alternatively 60 days from date of receipt of RM from Main producers/s - SAIL / TATA / JINDAL / RINL	This shall be addressed at the time of issue of RO
3	Annex II B, Sr No. 8, Inspection	TPC reserves the right to select random samples	TPCODL to confirm whether the random sample selected for testing, delivery of the same will be taken by TPCODL, as sample so drawn will result in 1 full length getting wasted / scrapped.	No, the sample for testing should be include in BA scope.
4	Annex 1 - Price Schedule	Line item 1,2 & 3	No mention about Stiffner Base Plates whether rates have to be quoted with Stiffner Base Plates	YES, Rates have to be quoted considering supply of both GI stiffner & Base Plate, which should be welded to the pole at the time of supply.
5	WPB 160 x 160 mm , Sr.No.5 - Dimensions & Properties and Remarks after Sr.No.6 - Mechanical Properties	BA has to supply baseplate - 300 x 300 x 12 mm and stiffners 150 x 60 x 6 and 150 x 100 x 6	Plse clarify these have to be welded with the WPB Poles or supplied seperately	Per Pole, 1 base plate & 4 number of stiffners as per drawing. These have to Pre fabricated & welded with the WPB poles. NO Separate Supply.
6	RSJ 100 x 116 mm , Sr.No.15	Supply of GI Base Plate with Stiffener	Plse clarify the sizes/dimensions of Base Plate and Stiffeners and whether these to be welded with the RSJ Poles or supplied seperately	Not applicable.This Tender only for WPB 160X160.
7	Drg's No. TPD-ODS-202-C-001	Foundation details for WPB/RSJ Joist for 33 kV Line	Drawings of Stiffner not clear wrt. To tech.deviations @ Sr.No.4 where is Stiffner 150 x 100 x 6 mm	There are total 4 no.s of Stiffners required per Pole. 2 no. of stiffner of size 150mm X 60mm X 6mm & 2 no's. of Stiffner 150mm x 100mm x 6mm. For details Refer drawing attached.
8	Drg's No. TPD-ODS-202-C-002	Foundation details for RS JOIST for 11 kV LINE	Drawings of Stiffner not clear wrt. To tech.deviations @ Sr.No.4 where is Stiffner 150 x 100 x 6 mm	There are total 4 no.s of Stiffners required per P+E14+A15:E20+A14:E20+A13:E20+E14+A15:E20

FORMAT B.2**Format for Commercial Pre-Bid Queries****Tender No** TPCODL/P&S/100000021/20-21**Package Name** Rate Contract for Supply of Galvanized Wide Parallel Beam (WPB) Pole .**Bidder :****Note :** The said format to be used only for Commercial Pre-Bid Query. Any Technical Query has to be strictly in Format B1 Format for Technical Pre-Bid Query and sent separately
Format to be used for query regarding Tender Notice, Commercial Pre-Qualification Requirement, Terms and Conditions, Other Formats / templates**Pre-Bid Query has to be sent in editable Excel file format only****Pre-Bid Query has to be sent through e-mail in Tata Power E-Tender System**

Sr. No.	Detailed Reference to Tata Power Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	Sr No. 7.1 Special Condition of Contract	After finalization, RC shall be issued to successful bidder... for 1 year, Rates shall be firm	Confirm that rates are variable as per applicable IEEMA PV formula	Yes
2	Sr No. 7.1 Special Condition of Contract	BA to submit 5% PBG for entire RC value	VTPL proposes that 5% PBG be submitted as per individual PO's issued against the RC from time to time to save Bank limits blockage of BA and also save costs to TPCODL	It is 5% of RC value or 10% of each RO value.
3	Sr No. 7.1 Special Condition of Contract	Delivry shall be within 60 days from date of "Release Order"	Delivery shall be within 90 days from issuance of "Release Order" as RM is from Main producer/s - SAIL / TATA / JINDAL / RINL is never delivered in timely manner or Alternatively 60 days from date of receipt of RM from Main producers/s - SAIL / TATA / JINDAL / RINL	This shall be addressed during issue of RO
4	Sr No. 7.5 Payment terms	Payment shall be released in 90 days from submission of certified bills	VTPL is an MSME approved, so we cannot accept 90 days payment terms, either it should be 90 days LC or 45 days MSME from date of receipt of certified bills	Payment term is 30 days from date of receipt of certified bill.
5	Annx. II, SCC, Sr No. 5 Delivery Period	The material shall be delivered within 60 days from issue of appvd. drg's or issue of RO whichever is later	Delivery shall be within 90 days from issuance of "Release Order" as RM is from Main producer/s - SAIL / TATA / JINDAL / RINL is never delivered in timely manner or Alternatively 60 days from date of receipt of RM from Main producers/s - SAIL / TATA / JINDAL / RINL	As mentioned in clause no 3 above.
6	Annx. II, SCC, Sr No. 6 Payment terms	Payments will be released within 90 days from date of submission of certified invoices at designated counter	VTPL is an MSME approved, so we cannot accept 90 days payment terms, either it should be 90 days LC or 45 days MSME from date of receipt of certified bills	As mentioned in clause no 4 above.
7	Annexure 1, Note 1 & VIII	Rates shall be Firm & PV prices	This terms contradicts with each other, clarify which is applicable.	PV clause is applicable.
8	Destination	NESCO Stores	TPCODL to provide stores location and addresses of each NESCO stores.	It is not NESCO but TPCODL. Delivery location may be any location under TPCODL jurisdiction.

