

Ref: TPCODL/P&S/1000000085/2021-22

**Sub: Corrigendum – II**

(i) Amendment of Tender Clauses:

Clause Ref.	Content	Existing	Amended as
7.1	"Special Conditions of Contract"	Warranty period 60 months from the date of last supplies made under the contract .	"Warranty period 120 months from the date of last supplies made under the contract ."  Warranty has to be marked on the nameplate of the enclosure with another warranty sticker (Metal Riveted) to be placed inside the enclosure with date and other details related to warranty.
Under Section 5.4	"ENCLOSURE"	1. 25 KVA Distribution box - 500x500x1000 (LXWXH) mm 2. 63 KVA Distribution box - 1000x500x1010 (LXWXH) mm 3. 100 KVA Distribution Box - 1000x500x1010 (LXWXH) mm 4. 250 KVA Distribution box- 1400x500x1200(LXWXH)mm 5. 500 KVA distribution box- 1400x500x1200(LXWXH) mm	1. For 25KVA Distribution box : 1000X500X170 (HxLxW) mm 2. For 63KVA Distribution box : 1010x1000x325 (HxLxW) mm 3. For 100KVA Distribution box : 1010x1000x325 (HxLxW) mm 4. For 250KVA Distribution box : 1800x1600x500 (HxLxW) mm 5. For 500KVA Distribution box : 2300x2500x500 (HxLxW) mm
Additional Clause under "Waste Handling after End of Life Cycle" added to this tender.		As per the guidelines issued by NGT/MOEF/CPCB and as per "Plastic Waste Management Rules 2016", we need to make sure that, the collection of waste generated by SMC/FRP Enclosures at the end of the useful life for recycling/re-use/proper disposal to be done. Following this rule, Vendor has to specify the useful life of the enclosure supplied by them. It will be the sole responsibility of the vendor to collect the waste of the enclosures supplied by them at the end of the product life cycle.	

All other terms and conditions of the above open tender remain unaltered.

By Order,  
Chief (Procurement & Stores)