



**Ref: TPCODL/P&S/1000000130/2021-22 /Corrigendum/001**

**Dated:** 24<sup>th</sup> November 2021

**Sub: Corrigendum-1 to Open tender number TPCODL/P&S/1000000130/2021-22 for Rate Contract for Supply of GI Pipe**

With reference to above the bidder are intimated to note the following intimations:

- I. **TPCODL is sharing replies to Pre-Bid queries raised by all the bidders seeking clarification before the deadline date as mentioned in Event Calendar of Tender Document No. TPCODL/P&S/1000000130/2021-22 of the Tender. The replies to Pre-bid queries is attached as Annexure-I to this Corrigendum**

**Note:**

- I. Bidder need to upload original signed Price bid along with copy of Price bid in Excel file in SAP Ariba
- II. All other terms and conditions of the above tender will remain same

**By Order**  
**Chief-Procurement & Store, TPCODL**



**ANNEXURE – I – Replies to Pre-Bid Queries**

<b>Sr. No.</b>	<b>Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No</b>	<b>Description as per Bid Document</b>	<b>Remarks - Query / Clarification</b>	<b>TPCODL RESPONSE</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
1	Technical Specification for Specifications for GI earth pipe (nominal bore-40 mm, Length-3 meter) Page No: 71	Technical Specification for Specifications for GI earth pipe (nominal bore-40 mm, Length-3 meter) Page No: 72	As shown in the drawing Earthing Pipe should be welded with Cone / Funnel or not to be specified for clarification.	Funnel / cone is not required in this Tender. Remaining all all material shall remain same.
2	Clause 3.5 of page 12	Bid shall remain valid for 180 days from the due date of submission of the bid and price variation clause is not applicable	Due to present trend of increase of raw material price, request you to include price variation clause with the price schedule to enable us to quote competitive price.	The price shall remain firm and fixed prices for 1 year. Bidders need to quote accordingly.